


MECH. EQUIPMENT RM., A-201
DEMOLITION PLAN
1/16" = 1'-0"

1. THE ELECTRICAL DEMOLITION DRAWINGS INDICATE MAJOR ELECTRICAL ITEMS TO BE REMOVED. THE ELECTRICAL DEMOLITION DRAWINGS ARE INTENDED TO INDICATE THE GENERAL SCOPE OF WORK REQUIRED AND DO NOT INDICATE EVERY FIRE ALARM DEVICE, GENERAL, WIRE, JUNCTION BOX, ETC. THAT MUST BE REMOVED. THE CONTRACTOR SHALL REMOVE ALL ITEMS WHICH ARE NOT REQUIRED TO REMAIN FOR REUSE.

GENERAL NOTES

DEMOLITION NOTES

- 1 REMOVE FIRE ALARM CONTROL PANEL AND TROUBLE BELL.
- 2 REMOVE FIRE ALARM ANNUNCIATOR PANEL.
- 3 REMOVE SMOKE/HEAT DETECTOR.
- 4 REMOVE AUDIO/VISUAL UNITS.
- 5 REMOVE MANUAL PULL STATION.
- 6 REMOVE DUCT SMOKE DETECTORS AND ASSOCIATED CONTROL/TEST PANEL BELOW.



- GENERAL NOTES**
1. THE ELECTRICAL DEMOLITION DRAWINGS INDICATE MAJOR ELECTRICAL ITEMS TO BE REMOVED. THE ELECTRICAL DEMOLITION DRAWINGS ARE INTENDED TO INDICATE THE GENERAL SCOPE OF WORK REQUIRED, AND DO NOT INDICATE EVERY ELECTRICAL DEVICE, CONDUIT, WIRE, JUNCTION BOX, ETC. THAT MUST BE REMOVED. THE CONTRACTOR SHALL REMOVE ALL ITEMS WHICH ARE NOT REQUIRED TO REMAIN FOR REUSE.
 2. WHERE ITEMS ARE TARGETED FOR REMOVAL, IT SHALL ALSO INCLUDE ALL ASSOCIATED MOUNTING APPARATUS, CONDUIT, WIRE, ETC., UNLESS REMAINING FOR REUSE. THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE DISPOSAL OF ALL MATERIAL AND SCRAP THAT THE OWNER DOES NOT WANT TO RETAIN FOR REUSE. VERIFY, IN FIELD, THE ITEMS TO BE RETAINED WITH THE OWNER'S REPRESENTATIVE.
 3. THE CONTRACTOR SHALL VISIT BOTH SCHOOL SITES PRIOR TO SUBMITTING A BID AND VERIFY EXISTING CONDITIONS. ADDITIONAL COSTS ASSOCIATED WITH IDENTIFIED DIFFICULTIES DURING DEMOLITION OF ONE OR BOTH SITES WILL BE BORNE BY THE CONTRACTOR. IF THESE ITEMS ARE NOT DISCOVERED UNTIL AFTER A THOROUGH INVESTIGATION OF THESE SITES PRIOR TO SUBMITTING A BID.

DEMOLITION NOTES	
1	REMOVE FIRE ALARM CONTROL PANEL AND TROUBLE
2	REMOVE FIRE ALARM ANNUNCIATOR PANEL.
3	REMOVE SMOKE/HEAT DETECTOR.
4	REMOVE AUDIO/VISUAL UNITS.
5	REMOVE MANUAL PULL STATION.
6	REMOVE DUCT SMOKE DETECTORS AND ASSOCIATED C
7	REMOVE FLOW SWITCH.
8	REMOVE TAMPER SWITCH.

NOTE:
REMOVE
PLATES
BACK-BOLTS
INSTALL
TROL PA
CIATOR
F.A. CO

M/E DESIGN SERVICES
MECHANICAL/ELECTRICAL CONSULTING ENGINEERS
112 1/2 Unionsway East
Indianapolis, Indiana 46204
(210) 256-1914