

C	CONDUIT	ELECTRICAL CONTRACTOR/TRADE
E.C.T.	EXIST.	EXIST.
U.C.	UNDER CEMENT	UNDER CEMENT CONTRACTOR/TRADE
S	SINGLE POLE SWITCH	SINGLE POLE SWITCH
S ₃	THREE-WAY SWITCH	THREE-WAY SWITCH
⊕	DUPLEX RECEPTACLE	DUPLEX RECEPTACLE WITH INTEGRAL GROUND FAULT INTERRUPTER
⊕	FLOOR RECEPTACLE PLUSH WITH FLOOR PROVIDE CARPET FLANGE WHERE REQUIRED	FLOOR RECEPTACLE PLUSH WITH FLOOR PROVIDE CARPET FLANGE WHERE REQUIRED
⊕	FLOOR MOUNTED DATA OUTLET	FLOOR MOUNTED DATA OUTLET
◀	DATA OUTLET WITH 1" TO ABOVE ACCESSIBLE CEILING BY OWNER OPEN UP TO EXISTING COMPUTER MAINFRAME BY OWNER	DATA OUTLET WITH 1" TO ABOVE ACCESSIBLE CEILING BY OWNER OPEN UP TO EXISTING COMPUTER MAINFRAME BY OWNER
⊕	FLOOR MOUNTED TELEPHONE OUTLET	FLOOR MOUNTED TELEPHONE OUTLET
◀	TELEPHONE OUTLET WITH 1" TO ABOVE ACCESSIBLE CEILING (DOUBLE GANG 3-BOX WITH BLANK COVER PLATE)	TELEPHONE OUTLET WITH 1" TO ABOVE ACCESSIBLE CEILING (DOUBLE GANG 3-BOX WITH BLANK COVER PLATE)
⊕	MOTOR LOCATION	MOTOR LOCATION
⊕	NO FUSE DISCONNECT SWITCH, 3DA OR AS NOTED.	NO FUSE DISCONNECT SWITCH, 3DA OR AS NOTED.
⊕	CONTROL CONNECTION	CONTROL CONNECTION
⊕	JUNCTION BOX	JUNCTION BOX
⊕	THERMOSTAT	THERMOSTAT
■	SWITCH	SWITCH
⊕	"A" = LIGHT FIXTURE TYPE FROM SCHEDULE also = LIGHT CONTROL	"A" = LIGHT FIXTURE TYPE FROM SCHEDULE also = LIGHT CONTROL
⊕	WIRE AND CONDUIT SIZE OTHER THAN MINIMUM SPECIFIED.	WIRE AND CONDUIT SIZE OTHER THAN MINIMUM SPECIFIED.
⊕	CONDUIT SIZE	CONDUIT SIZE
⊕	WIRE SIZE	WIRE SIZE
⊕	NUMBER OF WIRES	NUMBER OF WIRES
⊕	CONDUIT AND WIRE	CONDUIT AND WIRE
⊕	HOME RUN TO PANELBOARD, A1.3 = PANELBOARD A ₁ CIRCUITS 1 AND 3, THREE CROSS LINES AND WIRE SIZES ARE THE MINIMUM AS REQUIRED BY THE SPECIFICATIONS. LONG CROSS LINE = NEUTRAL	HOME RUN TO PANELBOARD, A1.3 = PANELBOARD A ₁ CIRCUITS 1 AND 3, THREE CROSS LINES AND WIRE SIZES ARE THE MINIMUM AS REQUIRED BY THE SPECIFICATIONS. LONG CROSS LINE = NEUTRAL
⊕	CONDUIT DISCONNECT SWITCH/MAGNETIC MOTOR STARTER	CONDUIT DISCONNECT SWITCH/MAGNETIC MOTOR STARTER
⊕	RECEPTACLE WITH 1" TO ABOVE ACCESSIBLE CEILING BY OWNER NOTED "A" = 1" UNLESS NOTED "A" WITH RECEPTACLE SYMBOL = 4" MOUNTING HEIGHT	RECEPTACLE WITH 1" TO ABOVE ACCESSIBLE CEILING BY OWNER NOTED "A" = 1" UNLESS NOTED "A" WITH RECEPTACLE SYMBOL = 4" MOUNTING HEIGHT
⊕	CABLE TO ROUGH-IN WITH 1" TO ABOVE ACCESSIBLE CEILING BY OWNER	CABLE TO ROUGH-IN WITH 1" TO ABOVE ACCESSIBLE CEILING BY OWNER
⊕	DATA MOUNTED CLOAK, DATE AND MANUFACTURER TO MATCH EXISTING. CONNECT TO EXISTING EQUIPMENT AS REQUIRED	DATA MOUNTED CLOAK, DATE AND MANUFACTURER TO MATCH EXISTING. CONNECT TO EXISTING EQUIPMENT AS REQUIRED
⊕	GELING MOUNTED SPEAKER. CONNECT TO EXISTING SOUND	GELING MOUNTED SPEAKER. CONNECT TO EXISTING SOUND

* REFERENCE DRAWING A-1 FOR ALTERNATE LIGHTING BID

