

208V/120V. PANELBOARDS IN THE MAIN BUILDING

PANELBOARD : 2BL3 VOLTAGE: 3 PHASE, 4 WIRE + GND. AMP'S: 225 M.L.O									
PLAN TYPE :	208V/120V	NOOD	SURF.	ROOM :	0213				
LOAD DESCRIPTION	C/B C/B	C/R	PHASE	NO.	C/R	C/B	C/B	LOAD DESCRIPTION	
SPARE	1	20	A	2	20	1	20	SPARE	
SPARE	2	20	B	3	20	2	20	SPARE	
RECEP.TS	1	20	9	6	20	1	20	RECEP.TS	
W.C.	1	20	7	A	10	20	1	RECEP.TS	EF-B1, B2
W.C.	1	20	11	A	12	20	1	RECEP.TS	EF-B3, B4, B5, B6
W.C.	1	20	13	A	14	20	1	RECEP.TS	EF-B8
RECEP.TS	1	20	15	A	16	20	1	RECEP.TS	EF-B9
RECEP.TS	1	20	17	A	18	20	1	RECEP.TS	EF-B10, B11, B12
RECEP.TS	1	20	19	A	20	20	1	RECEP.TS	EF-B13, B14
HAND DRIVER	1	20	21	A	22	20	1	RECEP.TS	EF-B15, B16, B17
HAND DRIVER	1	20	23	A	24	20	1	RECEP.TS	
HAND DRIVER	1	20	25	A	26	20	1	RECEP.TS	
HAND DRIVER	1	20	27	A	28	20	1	RECEP.TS	
HAND DRIVER	1	20	29	A	30	20	1	RECEP.TS	
HAND DRIVER	1	20	31	A	32	20	1	RECEP.TS	
HAND DRIVER	1	20	33	A	34	20	1	RECEP.TS	
HAND DRIVER	1	20	35	A	36	20	1	RECEP.TS	
SPARE	1	20	37	A	38	20	1	SPARE	
SPARE	1	20	39	A	40	20	1	SPARE	
SPARE	1	20	41	A	42	20	1	SPARE	
FEED FROM : SEE RISER 0.0 LIGHTS 12.9 MOTORS PROJECT NAME: CHESTERTON HIGH SCHOOL									
CONNECTED LOAD KVA : 13.8 MISCH/HEATING									

PANELBOARD : 2BL4 VOLTAGE: 3 PHASE, 4 WIRE + GND. AMP'S: 225 M.L.O									
PLAN TYPE :	208V/120V	NOOD	SURF.	ROOM :	0219				
LOAD DESCRIPTION	C/B C/B	C/R	PHASE	NO.	C/R	C/B	C/B	LOAD DESCRIPTION	
SPARE	1	20	A	2	20	1	20	SPARE	
SPARE	1	20	B	3	20	2	20	SPARE	
RECEP.TS	1	20	7	A	10	20	1	RECEP.TS	
RECEP.TS	1	20	11	A	12	20	1	RECEP.TS	
RECEP.TS	1	20	13	A	14	20	1	RECEP.TS	
RECEP.TS	1	20	15	A	16	20	1	RECEP.TS	
RECEP.TS	1	20	17	A	18	20	1	RECEP.TS	
RECEP.TS	1	20	19	A	20	20	1	RECEP.TS	
FUME HOOD	1	20	21	A	22	20	1	FUME HOOD	
FUME HOOD	1	20	23	A	24	20	1	FUME HOOD	
FUME HOOD	1	20	25	A	26	20	1	FUME HOOD	
FUME HOOD	1	20	27	A	28	20	1	FUME HOOD	
FUME HOOD	1	20	29	A	30	20	1	FUME HOOD	
RECEP.TS	1	20	31	A	32	20	1	RECEP.TS	
RECEP.TS	1	20	33	A	34	20	1	RECEP.TS	
RECEP.TS	1	20	35	A	36	20	1	RECEP.TS	
SPARE	1	20	37	A	38	20	1	SPARE	
SPARE	1	20	39	A	40	20	1	SPARE	
SPARE	1	20	41	A	42	20	1	SPARE	
FEED FROM : SEE RISER 13.0 LIGHTS 4.9 MOTORS PROJECT NAME: CHESTERTON HIGH SCHOOL									
CONNECTED LOAD KVA : 13.2 MISCH/HEATING									

PANELBOARD : 2BL5 VOLTAGE: 3 PHASE, 4 WIRE + GND. AMP'S: 225 M.L.O									
PLAN TYPE :	208V/120V	NOOD	SURF.	ROOM :	0219				
LOAD DESCRIPTION	C/B C/B	C/R	PHASE	NO.	C/R	C/B	C/B	LOAD DESCRIPTION	
SPARE	1	20	A	2	20	1	20	SPARE	
SPARE	1	20	B	3	20	2	20	SPARE	
RECEP.TS	1	20	7	A	10	20	1	RECEP.TS	
RECEP.TS	1	20	11	A	12	20	1	RECEP.TS	
RECEP.TS	1	20	13	A	14	20	1	RECEP.TS	
RECEP.TS	1	20	15	A	16	20	1	RECEP.TS	
RECEP.TS	1	20	17	A	18	20	1	RECEP.TS	
RECEP.TS	1	20	19	A	20	20	1	RECEP.TS	
FUME HOOD	1	20	21	A	22	20	1	FUME HOOD	
FUME HOOD	1	20	23	A	24	20	1	FUME HOOD	
FUME HOOD	1	20	25	A	26	20	1	FUME HOOD	
FUME HOOD	1	20	27	A	28	20	1	FUME HOOD	
FUME HOOD	1	20	29	A	30	20	1	FUME HOOD	
RECEP.TS	1	20	31	A	32	20	1	RECEP.TS	
RECEP.TS	1	20	33	A	34	20	1	RECEP.TS	
RECEP.TS	1	20	35	A	36	20	1	RECEP.TS	
SPARE	1	20	37	A	38	20	1	SPARE	
SPARE	1	20	39	A	40	20	1	SPARE	
SPARE	1	20	41	A	42	20	1	SPARE	
FEED FROM : SEE RISER 13.0 LIGHTS 3.5 MOTORS PROJECT NAME: CHESTERTON HIGH SCHOOL									
CONNECTED LOAD KVA : 13.1 MISCH/HEATING									

PANELBOARD : 2BL6 VOLTAGE: 3 PHASE, 4 WIRE + GND. AMP'S: 225 M.L.O									
PLAN TYPE :	208V/120V	NOOD	SURF.	ROOM :	0219				
LOAD DESCRIPTION	C/B C/B	C/R	PHASE	NO.	C/R	C/B	C/B	LOAD DESCRIPTION	
SPARE	1	20	A	2	20	1	20	SPARE	
SPARE	1	20	B	3	20	2	20	SPARE	
FLOOR BOX	1	20	7	A	10	20	1	FLOOR BOX	
FLOOR BOX	1	20	11	A	12	20	1	FLOOR BOX	
FLOOR BOX	1	20	13	A	14	20	1	FLOOR BOX	
FLOOR BOX	1	20	15	A	16	20	1	FLOOR BOX	
FLOOR BOX	1	20	17	A	18	20	1	FLOOR BOX	
FLOOR BOX	1	20	19	A	20	20	1	FLOOR BOX	
FLOOR BOX	1	20	21	A	22	20	1	FLOOR BOX	
FLOOR BOX	1	20	23	A	24	20	1	FLOOR BOX	
FLOOR BOX	1	20	25	A	26	20	1	FLOOR BOX	
FLOOR BOX	1	20	27	A	28	20	1	FLOOR BOX	
FLOOR BOX	1	20	29	A	30	20	1	FLOOR BOX	
FLOOR BOX	1	20	31	A	32	20	1	FLOOR BOX	
FLOOR BOX	1	20	33	A	34	20	1	FLOOR BOX	
FLOOR BOX	1	20	35	A	36	20	1	FLOOR BOX	
SPARE	1	20	37	A	38	20	1	SPARE	
SPARE	1	20	39	A	40	20	1	SPARE	
SPARE	1	20	41	A	42	20	1	SPARE	
FEED FROM : SEE RISER 17.2 LIGHTS 5.6 MOTORS PROJECT NAME: CHESTERTON HIGH SCHOOL									
CONNECTED LOAD KVA : 17.2 MISCH/HEATING									

PANELBOARD : 2BL7 VOLTAGE: 3 PHASE, 4 WIRE + GND. AMP'S: 225 M.L.O									
PLAN TYPE :	208V/120V	NOOD	SURF.	ROOM :	0139				
LOAD DESCRIPTION	C/B C/B	C/R	PHASE	NO.	C/R	C/B	C/B	LOAD DESCRIPTION	
SPARE	1	20	A	2	20	1	20	SPARE	
SPARE	1	20	B	3	20	2	20	SPARE	
RECEP.TS	1	20	7	A	10	20	1	RECEP.TS	
RECEP.TS	1	20	11	A	12	20	1	RECEP.TS	
RECEP.TS	1	20	13	A	14	20	1	RECEP.TS	
RECEP.TS	1	20	15	A	16	20	1	RECEP.TS	
RECEP.TS	1	20	17	A	18	20	1	RECEP.TS	
RECEP.TS	1	20	19	A	20	20	1	RECEP.TS	
RECEP.TS	1	20	21	A	22	20	1	RECEP.TS	
RECEP.TS	1	20	23	A	24	20	1	RECEP.TS	
RECEP.TS	1	20	25	A	26	20	1	RECEP.TS	
RECEP.TS	1	20	27	A	28	20	1	RECEP.TS	
RECEP.TS	1	20	29	A	30	20	1	RECEP.TS	
RECEP.TS	1	20	31	A	32	20	1	RECEP.TS	
RECEP.TS	1	20	33	A	34	20	1	RECEP.TS	
RECEP.TS	1	20	35	A	36	20	1	RECEP.TS	
RECEP.TS	1	20	37	A	38	20	1	RECEP.TS	
RECEP.TS	1	20	39	A	40	20	1	RECEP.TS	
RECEP.TS	1	20	41	A	42	20	1	RECEP.TS	
FEED FROM : SEE RISER 33.2 RECEPT 6.0 MOTORS PROJECT NAME: CHESTERTON HIGH SCHOOL									
CONNECTED LOAD KVA : 44.2 MISCH/HEATING									

PANELBOARD : 2BL8 VOLTAGE: 3 PHASE, 4 WIRE + GND. AMP'S: 225 M.L.O									
PLAN TYPE :	208V/120V	NOOD	SURF.	ROOM :	0139				
LOAD DESCRIPTION	C/B C/B	C/R	PHASE	NO.	C/R	C/B	C/B	LOAD DESCRIPTION	
SPARE	1	20	A	2	20	1	20	SPARE	
SPARE	1	20	B	3	20	2	20	SPARE	
RECEP.TS	1	20	7	A	10	20	1	RECEP.TS	
RECEP.TS	1	20	11	A	12	20	1	RECEP.TS	
RECEP.TS	1	20	13	A	14	20	1	RECEP.TS	
RECEP.TS	1	20	15	A	16	20	1	RECEP.TS	
RECEP.TS	1	20	17	A	18	20	1	RECEP.TS	
RECEP.TS	1	20	19	A	20	20	1	RECEP.TS	
RECEP.TS	1	20	21	A	22	20	1	RECEP.TS	
RECEP.TS	1	20	23	A	24	20	1	RECEP.TS	
RECEP.TS	1	20	25	A	26	20	1	RECEP.TS	
RECEP.TS	1	20	27	A	28	20	1	RECEP.TS	
RECEP.TS	1	20	29	A	30	20	1	RECEP.TS	
RECEP.TS	1	20	31	A	32	20	1	RECEP.TS	
RECEP.TS	1	20	33	A	34	20	1	RECEP.TS	
RECEP.TS	1	20	35	A	36	20	1	RECEP.TS	
RECEP.TS	1	20	37	A	38	20	1	RECEP.TS	
RECEP.TS	1	20	39	A	40	20	1	RECEP.TS	
RECEP.TS	1	20	41	A	42	20	1	RECEP.TS	
FEED FROM : SEE RISER 42.0 RECEPT 6.0 MOTORS PROJECT NAME: CHESTERTON HIGH SCHOOL									
CONNECTED LOAD KVA : 42.0 MISCH/HEATING									

PANEL BOARD										VOLTAGE: 3 PHASE, 4 WIRE + GND.				AMP'S: 225 M.L.O			
PLAN TYPE : 1DL3										208V/120V				NOOD SURF.		ROOM : D 42	
LOAD DESCRIPTION		C/B	C/B	C/R	PHASE	C/R	C/B	C/B	LOAD DESCRIPTION								
		POLE	AMP	NO.		POLE	AMP	NO.									
SPARE		1	20	1	A	2	20	1	SPARE								
SPARE		1	20	3	B	4	20	1	SPARE								
RECEP.TS		1	20	7	A	8	20	1	RECEP.TS								
RECEP.TS		1	20	9	B	8	20	1	RECEP.TS								
RECEP.TS		1	20	11	A	12	20	1	RECEP.TS								
RECEP.TS		1	20	13	A	14	20	1	RECEP.TS								
RECEP.TS		1	20	17	B	18	20	1	RECEP.TS								
RECEP.TS		1	20	19	A	20	20	1	RECEP.TS								
RECEP.TS		1	20	21	B	22	20	1	RECEP.TS								
RECEP.TS		1	20	23	C	24	20	1	RECEP.TS								
RECEP.TS		1	20	25	A	26	20	1	RECEP.TS								
RECEP.TS		1	20	27	B	28	20	1	RECEP.TS								
RECEP.TS		1	20	29	C	30	20	1	RECEP.TS								
RECEP.TS		1	20	31	A	32	20	1	RECEP.TS								
RECEP.TS		1	20	33	B	34	20	1	RECEP.TS								
RECEP.TS		1	20	35	C	36	20	1	RECEP.TS								
SPARE		1	20	37	A	38	20	1	SPARE								
SPARE		1	20	39	B	40	20	1	SPARE								
SPARE		1	20	41	C	42	20	1	SPARE								
FEED FROM : FEED RISER										LOADS NYA:				PROJECT NAME:			
CONNECTED LOAD NYA/SPARE										27.4 RECEPTS				CHOLESTATION			
33.4										0.0 MISWIRTHING				H 30 WATERS			
										0.0 SPARE				ROOM :			
														D 42			