



UNIT "E" = 35,117 SQ FT
TOTAL ZONE 1 = 35,117 SQ FT

SEE DWG FP-15 FOR UNIT "D"

ALL PIPE SLEEVES SHALL BE S30.4 GALV. PIPE
SLEEVES SHALL BE CUT FLUSH WITH WALL AND
GASKETS CHANGED BETWEEN NON-PARTIAL WALLS. SEE
PRACTICES 175
SLEEVES SHALL BE SIZED AS FOLLOWS:

SPRINKLER FRAMES	PIPE SIZE
1/2"	1/2"
3/4"	3/4"
1"	1"
1 1/4"	1 1/4"
1 1/2"	1 1/2"
2"	2"

75°
1/2"
1/4"
1/2"
1/4"
STEEL JOIST
1/2"
1/4"
1/2"
1/4"
ALL THREAD ROD
TRAP HANGER
PIPE

HANGER CL DETAIL - TYPICAL