



NOTE: DRAWINGS SUBMITTED ARE AN ALTERNATE DESIGN REQUESTED BY W.R.KELSO CO. NOT AS DESIGNED BY FANNING & HOWE, REF. QUOTE #970793 ALTERNATE DESIGN # 2 TAPER AND FILL ONLY.

- NOTES:
- 1) INSULATION SHOWN ON THIS DRAWING IS FOAMULAR BY UCI INDUSTRIES. INSULATION IS EXTRUDED POLYSTYRENE.
 - 2) LAY TAPERED BOARDS BY LETTERS AS INDICATED. THE NUMBERS FOLLOWING EACH LETTER REFER TO THICKNESS OF FILL BOARDS, AS PER CROSS-SECTION VIEW.
 - 3) ALL HIPS, VALLEYS AND CRICKETS ARE TO BE FIELD CUT. MATERIAL WILL BE SUPPLIED.
 - 4) ROOF DIMENSIONS USED TO DRAW THIS PLAN WERE FROM ARCHITECT'S PLANS SUBMITTED. THE ROOFING CONTRACTOR SHOULD CHECK DIMENSIONS BEFORE MATERIAL HAS BEEN MANUFACTURED AND CONTACT UCI INDUSTRIES OF ANY CHANGES. ANY ALTERATIONS AFTER PRODUCTION OF MATERIAL MAY RESULT IN ADJUSTMENT OF ORIGINAL PRICE.
 - 5) APPROVED SIGNED SHOP DRAWINGS MUST BE RETURNED TO UCI INDUSTRIES PRIOR TO RELEASE OF MATERIAL TO FABRICATION.
 - 6) MANUFACTURER IS NOT RESPONSIBLE FOR SAFEKEEPING NOR MATERIAL SHORTAGES AFTER SIGNING FOR RECEIPT OF UCI MATERIAL.
 - 7) IT IS REQUIRED THAT THE ROOFING MEMBRANE AND INSULATION BE BALLASTED IMMEDIATELY AFTER PLACEMENT. FOR MORE DETAILS PLEASE REFER TO CURRENT FOAMULAR LITERATURE OR CONTACT YOUR LOCAL UCI SALES REPRESENTATIVE.

- ① PAGE 1
- ② PAGE 2
- ③ PAGE 3
- ④ PAGE 4
- ⑤ PAGE 5
- ⑥ PAGE 6

THIS AREA IS NOT SHOWN ON ANY OF THE FOLLOWING PAGES.

COURTYARD

FORWARDED AND FORWARDED TO A/E
 DESIGN AND DESIGN
 DATE: 12/11/97
 CONSTRUCTION CONTROL
 FORT WAYNE, INDIANA

Extruded Polystyrene Insulation
FOAMULAR®
 OWENS CORNING
 SPECIALTY and FOAM PRODUCTS
 UCI INDUSTRIES, INC.

170 South Ave. P.O. Box 455
 Tallmadge, Ohio 44278
 1-800-873-1594 FAX (216) 633-7316
 TAPER CONTROL CENTER

Project: CHESTERTON H.S.
 SWIMMING POOL
 CHESTERTON, INDIANA

Architect: FANNING & HOWE

Material: THERMAPINK 25

Roofer: KELSO ROOFING

Scale: N.T.S. Drawn: T.L.I.
 Slope: VARIES Checked: R.E.G.
 Date: 11/3/97 T-218-97

Drawing number: COVER

REVISIONS

1. REVISED DRAWING FOR RELOCATION OF ROOF DRAINS PER W. R. KELSO.

SHOP DRAWING/SUBMITTAL REVIEW STATUS	
ARCHITECT'S DETERMINATION	RESPONSE REQUIRED
No Exceptions Taken <input checked="" type="checkbox"/> Rejected <input type="checkbox"/>	Confirm <input type="checkbox"/>
Note Markings <input type="checkbox"/> Comments Attached <input checked="" type="checkbox"/>	Resubmit <input checked="" type="checkbox"/>
<small>Architect's review is only for checking conformance with the 3-1/2" minimum depth, and with the design. Approval is not a warranty. The Contractor is responsible for the design and construction of the roof system. The Contractor is responsible for the design and construction of the roof system. The Contractor is responsible for the design and construction of the roof system.</small>	
<small>ARCHITECTS/ENGINEERS</small> By: LEC Date: 2-6-98	

New drawings have been modified by manufacturer and being resubmitted.

☐ APPROVED
☒ APPROVED AS NOTED
☐ MAKE CORRECTIONS-RESUBMIT
☐ NOT APPROVED-RESUBMIT
 REVIEW IS ONLY FOR CONFORMANCE WITH THE DESIGN CONCEPT OF THE PROJECT AND COMPLIANCE WITH THE INFORMATION GIVEN ON THE CONTRACT DOCUMENTS. APPROVAL DOES NOT RELIEVE YOUR RESPONSIBILITY FOR DIMENSIONS TO BE CONFIRMED AT THE SITE OR FOR INFORMATION PERTAINING SOLELY TO FABRICATION PROCESSES OR CONSTRUCTION TECHNIQUES OR FOR QUANTITIES REQUIRED FOR COMPLETE JOB.
 W.R. KELSO CO., INC.
 DATE: 11-3-97 BY: LEC
 PROJECT: CHESTERTON H.S. SWIMMING POOL

W.R. Kelso - Tap. Insul. Dwg. (1st SW)

97-SWP-01