

[illegible]

- A. FLUORESCENT FIXTURES IN THE UNBEL. AREA SHALL BE CONTRACTOR SHALL REMOVE THE LAMPS, BALLAST FOR REPLACEMENT.
- B. INTERCOM SYSTEM - ALL SPEAKERS AND CALL SWITCHES SHALL BE DISCONNECTED AND REMOVED.
- C. EXISTING CABLE TRAY SHALL REMAIN. DISCONNECT AND REMOVE ALL CONDUCTIONS NOT BEING USED IN THE RENOVATION WORK.

LOWER LEVEL KEY PLAN

NORTH

SCALE: 1/6" = 1'-0"

A B C D E F G H

**ARCHITECT
ENGINEER
PLANNERS**

RENOVATION PROJECT FOR:
DUNEAND SCHOOL CORP.
CHESTERTON HIGH SCHOOL/MIDDLE SCHOOL
CHESTERTON, INDIANA

DEMOLITION PLAN - TUNNEL

Project No: 999999

Project Date: 11/15/2000

Drawn By: BWH

Approved By: TLM

Drawing No. **E 0.0**

2000-E-03