

[illegible]


- A. ALL LIGHTING SWITCHES INDICATED SHALL BE REMOVED FOR REPLACEMENT WITH NEW DEVICES.
- B. INTERCOM SYSTEM - ALL SPEAKERS AND CALL SWITCHES SHALL BE DISCONNECTED AND REMOVED.
- C. CLOCK SYSTEM - ALL CLOCKS SHALL BE DISCONNECTED AND REMOVED.

- 1 DISCONNECT AND REMOVE ALL ELECTRICAL WORK IN THIS AREA, IN LESS OTHERS ARE NOTED.
- 2 DISCONNECT AND REMOVE ALL LIGHTING FIXTURES, INTERCOM SYSTEMS, SPEAKER DEVICES, IN-CAVITIES AND ALL OTHERS IN THE AREA. REMOVE ALL CAVES, LUMENES AND REMOUNT THEM IN NEW CAVES AT SAME LOCATION.
- 3 DISCONNECT AND REMOVE ALL LIGHTING FIXTURES, CEILING PANELS AND LIGHTING. LIGHTING CIRCUIT TO REMAIN FOR CONNECTION TO NEW LIGHTING FIXTURES AND PANELS. SEE REBAR DRAWINGS ON SHEET E-502 & E-501 FOR PANELS AND DISTRIBUTION PANELS AND SWITCHBOARDS.
- 4 DISCONNECT AND REMOVE THE LAMP, BALLAST, LUMENES, COMPACTOR FOR SMALL REMOVE THE LAMP, BALLAST, LUMENES AND LIGHTING FIXTURE.
- 5 DISCONNECT REBAR CIRCUIT FROM EXISTING ELEVATOR DISCONNECT TO EXIST PANEL #1. DISCONNECT TO REMAIN FOR RECONNECTION TO NEW CAVES.
- 6 REBAR ATTACHED TO REMAIN ON THE LIGHTING REBAR. LIGHTING CIRCUIT TO REMAIN FOR CONNECTION TO NEW LIGHTING FIXTURES AND PANELS.

ARCHITECTS
ENGINEERS
PLANNERS

628 Main Street
Suite 400
Kearneyville, Ia 47701

RENOVATION PROJECT FOR:
DUNELAND SCHOOL CORP.
CHESTERTON HIGH SCHOOL/MIDDLE SCHOOL
CHESTERTON, INDIANA

	Project No. 9980.00 Project Date: JUNE 2000 Drawn By: EMM Approved By: TLM Drawing No. E 0.9
-----------------------------------------------------------------------------------	----------------------------------------------------------------------------------------------------------

2000-E-12