


1 ADMINISTRATION/MAINTENANCE BUILDING - LOFT FLOOR PLAN - POWER
1/8" = 1'-0"

- ### GENERAL NOTES
1. ALL DEVICES IN UNFINISHED STORAGE AND GARAGE SPACES SHALL BE MOUNTED TO STEEL FRAMING ONLY. HOLES SHALL NOT BE CUT INTO THE METAL BUILDING.
 2. SURFACE MOUNTED RACEWAYS SHALL BE PROVIDED AT ALL OCCUPIED SPACES - COLOR TO BE SELECTED BY ARCHITECT.
 3. SURFACE MOUNTED CONDUIT AND KNOCK BOXES ARE TO BE PROVIDED AT ALL STORAGE AND GARAGE SPACES.
 4. PANEL LOCATIONS SHALL BE VERIFIED IN FIELD BY CONTRACTOR.



E0.11

PROJECT NUMBER: 14-208	REVISIONS:
PROJECT MANAGER: EF	
DRAWN BY: EF	
DATE FOR PROPOSAL: 06/07/2016	
ADMINISTRATION / MAINTENANCE BUILDING LOFT FLOOR PLAN - POWER	



DUNELAND SCHOOL CORPORATION
BUS BARN FIRE ALARM RENOVATION
ADMINISTRATION / MAINTENANCE BUILDING / BUS BARN
1012 N. OLD STATE RD. 49
CHESTERTON, INDIANA 46304

Miss Engineering Group
P/E: 10/10/2010
P/E: 10/10/2010

