WIRING NOTES

1. LIGHTING FIXTURES IN GENERAL PURPOSE & DINING AREA SHALL BE WIRED SO THAT THE TWO INBOARD LAMPS IN EACH FIXTURE ARE CONNECTED TO THE EVEN NUMBERED CIRCUIT & THE TWO OUTBOARD LAMPS ARE CONNECTED TO THE ODD NUMBERED CIRCUIT.
2. THE MOMENTARY CONTACT SWITCHES (4) IN THE GENERAL PURPOSE & DINING AREA AND ON THE STAGE SHALL BE WIRED IN PARALLEL AND SHALL CONTROL THE CONTACTOR IN LP-D

ALTERNATE PLAN

EMERGENCY LIGHT CONTROL STATION
3#12-3/4"C TO CONTACTOR IN LP-EM.

LP-B LOCATED IN FAN RM. ABOVE

EMPTY 3/4"C UP TO LP-B FOR LIGHTING UNDER FUTURE MEZZANINE

NO	PRINTS & SPECIFICATIONS	BY	DATE
3	Dodge	EG	4-4
2	Office	EG	4-4
1	Bid Purposes	EG	4-4

NO	REVISIONS - THUS	BY	DA

WESTCHESTER TOWNSHIP ELEMENTARY SCHOOL

5TH STREET & UNION AVENUE
CHESTERTON INDIANA

FOR THE

WESTCHESTER TOWNSHIP SCHOOL CORPORATION

LIGHTING PLA

The Perkins & Will Partnership

ARCHITECT

320 West Jackson B
Chicago Illinois 606
Phone 312-427-2

DATE 6-21-66
PROJECT NO. 21970.5
DRAWN BY H.B.
CHECKED BY F.C.S.
DEPT. HEAD SCHARRES
PROJ. ARCH. P. SPAULDING

E-601.

FLOOR PLAN
SCALE : 1/8"=1'-0"

SCHARRES & ASSOCIATES
CONSULTING ENGINEERS
RIVERSIDE PLAZA CHICAGO, ILLINOIS