

LIGHTING CONTROL NOTES:


1. LIGHTING CONTROL BASIS OF DESIGN IS nLIGHT. PROVIDE COMPONENTS THAT MEET THE DESCRIPTIVE REQUIREMENTS BELOW BY nLIGHT, OR EQUAL. CONTACT RANDY DANA AT (630) 338-7308 FOR ADDITIONAL INFORMATION.
2. PROVIDE PERIPHERAL COMPONENTS AS REQUIRED FOR A COMPLETE OPERATIONAL SYSTEM, WHETHER SPECIFICALLY INDICATED OR NOT.
3. PROVIDE (2) SWITCHES WITHIN RECEPTION AREA TO CONTROL 1st FLOOR AND 2nd FLOOR CORRIDOR LIGHTING.
4. UTILIZE CIRCUITS FROM DEMOLISHED LIGHTING FOR NEW LIGHTS. RE-WIRE AS REQUIRED TO ACCOMMODATE NEW LIGHTING CONTROLS.

ELECTRICAL KEY NOTES:

- 1 UNDER ALTERNATE BID, PROVIDE NEW LIGHTS AS INDICATED. RUN NEW WIRING AS REQUIRED TO ACCOMMODATE DIMMING AND SWITCHING.
- 2 CONNECT TO CORRIDOR'S SWITCHING CONFIGURATION.
- 3 EXISTING SPEAKERS TO BE RELOCATED TO INDICATED LOCATION. TIE SPEAKERS BACK INTO EXISTING SOUND SYSTEM.

LIGHTING CONTROL SYMBOLS:

- LV1 ON/OFF "a", ON/OFF "b", RAISE/LOWER 0-10V SWITCH
- LV2 ON/OFF, RAISE/LOWER 0-10V SWITCH
- LV3 (3) SCENES, RAISE/LOWER 0-10V SWITCH
- OS1 ON/OFF, WITH INTEGRAL IR OCCUPANCY SENSOR.
- OS2 ON/OFF, RAISE/LOWER 0-10V SWITCH WITH INTEGRAL IR OCCUPANCY SENSOR.
- OS CEILING MOUNTED 360° OCCUPANCY SENSOR
- OS- WALL MOUNTED DIRECTIONAL OCCUPANCY SENSOR
- DL CEILING MOUNTED DAYLIGHT SENSOR
- DP1 DIMMING POWER PACK




KEY PLAN
NOT TO SCALE




E1.20

DUNELAND SCHOOL CORPORATION
 2018 MAIN OFFICE RENOVATIONS AT:
 CHESTERTON MIDDLE SCHOOL (CMS)
 651 W. MORGAN AVENUE, CHESTERTON, INDIANA 46304

PROJECT NUMBER: 139-A-3	REVISION:
PROJECT MANAGER: KAC	
DRAWN BY: OAS	
ISSUED FOR BID: 03/20/2018	
PARTIAL SECOND FLOOR PLAN - LIGHTING	



DUNELAND SCHOOL CORPORATION
 2018 MAIN OFFICE RENOVATIONS AT:
 CHESTERTON MIDDLE SCHOOL (CMS)
 651 W. MORGAN AVENUE, CHESTERTON, INDIANA 46304



TRIA
 ARCHITECTURE

